



***SAFETY ADVISORY; KIDDE FIRE EXTINGUISHER RECALL***

Two types of Kidde fire extinguishers are being recalled for failure to discharge; one death has been reported. See the attached recall notice.

Please immediately remove those fire extinguishers from service. Recommend replacing those fire extinguishers with commercial grade all metal construction type extinguishers.

Please inspect your facilities for Kidde fire extinguishers involved in the recall notice.

The two types of extinguishers, covering eight models are being recalled. The extinguishers involved are plastic handle fire extinguishers and push-button Pindicator fire extinguishers.

There have been 391 reports of failed or limited activation or nozzle detachment including one fatality, approximately 16 injuries and 91 reports of property damaged have been reported due failed operation of the Kidde fire extinguishers.

If you have any questions please contact;

Lei Wang, Facilities Inspector and Facilities Project Coordinator  
Office (408) 983-0240      Email: [lwang@dsj.org](mailto:lwang@dsj.org)

Theresa LaVoun, Loss Control and Loss Prevention Coordinator  
Office (408) 983-0237      Email: [LaVoun@dsj.org](mailto:LaVoun@dsj.org)

Ian Abell, Director Facilities, Insurance and Risk Management  
Office (408) 983-0223      Email: [iabell@dsj.org](mailto:iabell@dsj.org) Mobile (408) 813-7573

November 07, 2017